

**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Woodbury Heights Elementary School

100 Academy Avenue  
Woodbury Heights, NJ 08097

### Results of Lead Analysis


Date & Time Sampled: 04/18/2017 09:00 - 09:51

Date & Time Analyzed: 05/01/2017 16:06 - 16:39

Date & Time Analyzed: 05/02/2017 10:20 - 14:27

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
WHE-CR-WC-110	<2.00	15.5
WHE-CR-WF-108	4.81	15.5
WHE-N-S-FIRST	41.0	15.5
WHE-CR-WF-112	5.63	15.5
WHE-CR-WF-104	2.78	15.5
WHE-CR-WF-111	3.49	15.5
WHE-CR-WF-114	154	15.5
WHE-CR-WF-201	3.75	15.5
WHE-CR-WF-202	2.58	15.5
WHE-CR-WF-204	2.63	15.5
WHE-CR-WF-205	50.0	15.5
WHE-CR-WF-203	3.16	15.5
WHE-CR-WF-206	2.43	15.5
WHE-CR-WF-208	13.0	15.5
WHE-CR-WF-207	5.22	15.5
WHE-CR-WF-210	6.76	15.5
WHE-100-WF-64	<2.00	15.5
WHE-K-S-64	<2.00	15.5
WHE-FL-S-64	<2.00	15.5

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Woodbury Heights Elementary School

100 Academy Avenue  
Woodbury Heights, NJ 08097

### Results of Lead Analysis

Date & Time Sampled: 04/18/2017 09:00 - 09:51

Date & Time Analyzed: 05/01/2017 16:06 - 16:39

Date & Time Analyzed: 05/02/2017 10:20 - 14:27

Sample Location	Sample Result	Action Level
WHE-CR-WF-105	4.22	15.5
WHE-CR-WF-106	3.01	15.5
WHE-CR-WF-103	2.54	15.5
WHE-CR-WF-104	5.92	15.5
WHE-CR-WF-101	2.95	15.5
WHE-CR-WF-102	3.21	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

5/15/17  
Date