


WOODBURY HEIGHTS SCHOOL DISTRICT

100 Academy Avenue
Woodbury Heights, NJ 08097-1499
Phone: 856-848-2610
Fax: 856-848-8739



Janis Gansert
Chief School Administrator

Christopher Rodia
Business Administrator

May 17, 2017

Dear Parents, Guardians and Staff:

Woodbury Heights School District contracted with South Jersey Water Test, LLC of Williamstown, NJ to conduct mandated State lead testing of water outlets in our school. These tested outlets included water fountains and sinks. Water samples were taken from Woodbury Heights Elementary School on 4/18/17, analyzed and verified by the laboratory on 5/2/17 and received by the district on 5/16/17. Three (3) of the 25 samples taken exceeded the US Department of Environmental Protection Agency (EPA) action levels of 15 ug/L {ppb}. PPB stands for parts per billion.

In accordance with the Department of Education regulations, we will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 ug/L (ppb). This includes turning off the outlet, unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK-SAFE FOR HAND WASHING ONLY" sign will be posted.

The table below identifies the drinking water outlets that tested above the 15 ug/L for lead, the actual lead level, and what temporary remedial action the Woodbury Heights School District is taking to reduce the levels of lead at this location. In the coming weeks we will be working on a solution to maintain a reduced lead level in these areas and conducting follow up testing.


Sample Location	First Draw result in ug/L (ppb)	Remedial Action
WHE-N-S-FIRST (Health Office Sink)	41	Posted Signage "Do not Drink-Safe for Hand Washing Only"
WHE-CR-WF-114 (Classroom Sink & Water Fountain)	154	Sink - Posted Signage: "Do not Drink-Safe for Hand Washing Only" Water Fountain - Not in Use; Disconnected outlet
WHE-CR-WF-205 (Classroom Sink & Water Fountain)	50	Sink - Posted Signage: "Do not Drink-Safe for Hand Washing Only" Water Fountain - Not in Use; Disconnected outlet

The EPA's protocol with any outlet that tests lead at or above 15 ug/L (ppb) is to proceed with a flush sample, which we have scheduled 5/18/17. A follow-up report will be shared when this action is completed.

The complete testing results are available on the front page of the school website at www.woodburyhtselem.com. For additional questions, please contact Chris Rodia at 856-848-8210.

For information about water quality and sampling for lead at home, contact your local water supplier or refer to the Department of Environmental Protection's website at <http://www.nj.gov/dep/watersupply/dwc-lead-schools.html>.

Sincerely,



Janis Gansert
Chief School Administrator